

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

B. 760, ERDA Boad, Makarpura Industrial Estate, Vadodara-390 010, India, Gram : ELECSEARCH

PARX : +91 (0265) 2642:42, 2642:961, 2642:377, 2642:557, 2635:300, 2635:253, 2657784, 2657785.

+91 (0265) 2638:332, F-mail : erda@erda.org : dir@erda.org : adir@erda.org



TEST REPORT

		Sheet 1 of 3
NAME AND ADDRESS OF CUSTOMER	REPORT NO. : PLV/06/IP/642 DATE : 24/06/2006	
FLECTRONIC SYSTEMS 921/3-C, GIDC Estate, Makarpura, Vadodara: 390 010. India.	CUSTOMER REF. NO. ES/JS/002	DATE 23/05/2006
	DATE OF SAMPLE RECEIPT	DATE OF TESTING
	23/05/2006	27/05/2006

SAMPLE DESCRIPTION

FCB BATTERY CHARGER AND DCDB

Rating 110V, 200AH

Containing MCB, Switch, Terminal. Bridge Rectifier, Fuse.

SAMPLE IDENTIFICATION

ERDA sample code no. : LSWGWO0041203/01

Drg. No.: DPSPL-01 (Rev. AB)

(sheet Lof 7)

Sr. No. : ES-02

TEST DETAILS

1.6 IP 43 tests

TEST SPECIFICATION

Tests as per

IS: 13947(part-1) = 1993/ IEC pub 947 + 1(1988)

Enclosures: Drg. No.: DPSPL-01 (Rev. AB) (sheet 1 of 7)

Test Witnessed by: Mr. J. S. Jinwala (Works Manager) of

M/s. Electronic Systems, Vadodara.

Remarks: The sample conforms to the requirements of IP 43 tests as per the standard.

Prepared by

Alle Healis

Checked by

Approved by

Note: 1. This report relates only to the particular sample received for testing in good condition at ERDA.

- 2. This report cannot be reproduced in part under any circumstances.
- 3. Publication of this report requires prior permission in writing from Director, ERDA.
- 4. Only test asked by the customer have been Carried out.